

made in Germany by





General building supervision approval DIBt- No.: Z-65.30-562



For gasoline DIN EN 2281 up to E20; alcohol DIN EN 14879-4, JET A1 and diesel DIN EN 5902

- General building supervision approval DIBt No. Z65.30-562
- Developed and tested together with the TÜV (German Technical Inspection Association), the PTB (National Metrology Institute of Germany) and the BAM (Federal Institute for Materials Research and Testing).
- Meets the requirements of DIN EN 13160-7: 2003 and the following DIN EN 13160-7: 2016




Fast installation - safe operation

- Installation of the tank casing only with short interruptions of the day-to-day business.
- Connection of accessories and leak detector is also possible without entering the tank.
- Effective leak protection and corrosion protection of the tank interior.



FENOSAFE® FUEL DIBt APPROVAL – THE PERMEATION IS 15-TIMES BELOW THE NORM



TANK LINER	FENOSAFE® FUEL	FENOSAFE® U	FENOSAFE® Blue	
DIBt-Approval No.	Z-65.30-562	Z-65.30-487	Z-65.30-487	
FUEL:				
Gasoline DIN EN 228 bis E20		-	-	
Alcohol DIN EN 14879-4		-	-	
JET A1		-	-	
Diesel DIN EN 590, up to 20% Biodiesel			-	
Heating oil EL DIN 51603-1	-		-	
AdBlue DIN 70070	-	-	•	